

LGA-Certificate No. 57214104 b
LGA-Certificate: Type tested and monitored

Holder of certificate: Wiedemann GmbH
Siemensstraße 16 - 18
25813 Husum

**Manufacturer and
Manufacturing plant** as above

Products: Cover PRD-DRS-070-RD, (= PRD-DRSRR-070-RD),
PRD-DRSK-100-RD, PRD-DRS-100-RD, (= PRD-DRSRR-100-RD,
PRD-91-100-RD), PRD-DRS-150-RD, PRD-71-070-RD,
PRD-71-100-RD, PSD-88-100-RD, POD-88-100-RD,
POD-88N-100-RD, POD-DRS-070-RD, (= POD-DRSRR-070-RD),
POD-DRSK-100-RD, POD-DRS-100-RD, (= POD-DRSRR-100-RD),
POD-DRS-150-RD, POD-71-070-RD, POD-71-100-RD,
POD-88N-100-RD und Cover POD-88-100-RD
all Class M 125

The above mentioned products have been tested according to the standard and are regularly third party controlled. They are in accordance with the requirements of DIN EN 1253-1 and the odour tightness class Ot according to section 7.3.2 of the DIN EN 1253-4.


The detailed results of the regular inspection 2014 in the manufacturing plant are shown in the Inspection report no. 57214104-01 and test report no. 57214104-03 of the TRLP.

This certificate is valid until 31.12.2019.

The manufacturer is allowed to mark the above mentioned products with the LGA-sign "Type-tested and monitored".

Würzburg, 30.09.2014

TÜV Rheinland LGA Products GmbH
Zertifizierungsstelle für Sanitärprodukte und Abscheider



Dipl.-Ing. (FH) Fries
stellvertr. Leiter der Zertifizierungsstelle

